

# HOME & STRUCTURE FIREWISE ASSESSMENT

Circle any areas that need addressing.



## OVERVIEW OF SITE

Slope, prevailing winds, canopy of trees around structures, spacing of bushes & vegetation, type of construction.

## ROOF TO EAVES

Chimney, flashing, roof vents, gable vents, 1/8" minimum screen, roofing type & condition, debris in crevices, combustible materials on roof, clean.

## EAVES TO FOUNDATION

Eaves boxed in, gutters plastic or metal, free of debris, downspouts, vents 1/8" minimum screen, windows dual pane / tempered glass, metal screens, frames, siding, attachments, fences, decks, arbors, garage door sealed.

## FOUNDATION TO 3 TO 5 FEET HOME MARGIN

Combustibles against the siding, leaves, grass, bark mulch, flammable vegetation, juniper, sage, rosemary, wood piles, plastic deck patio furniture.

## 3 TO 5 FEET HOME MARGIN TO EXTENT OF HOME IGNITION ZONE

Defensible space, open canopy of trees, spacing between bushes, low hanging branches, ladder fuel. If you can't walk under the branches they're too low. 1/3 height of the tree.